§ 3280.113

the 28 inches required for passage. In addition, a notice of the available clearance for washer/dryer units shall be posted in the laundry area. Minor protrusions into the minimum hallway width by doorknobs, trim, smoke alarms or light fixtures are permitted.

[40 FR 58752, Dec. 18, 1975. Redesignated at 44 FR 20679, Apr. 6, 1979, and further redesignated at 58 FR 55004, Oct. 25, 1993; 67 FR 12817, Mar. 19, 2002]

§ 3280.113 Glass and glazed openings.

- (a) Windows and sliding glass doors. All windows and sliding glass doors shall meet the requirements of §3280.403 the "Standard for Windows and Sliding Glass Doors Used in Manufactured Homes".
- (b) Safety glazing. Glazing in all entrance or exit doors, sliding glass doors, units (fixed or moving sections), unframed glass doors, unbacked mirrored wardrobe doors (i.e., mirrors not secured to a backing capable of being the door itself), shower and bathtub enclosures and surrounds to a height of 6 feet above the bathroom floor level, storm doors or combination doors, and in panels located within 12 inches on either side of exit or entrance doors shall be of a safety glazing material. Safety glazing material is considered to be any glazing material capable of passing the requirements of Safety Performance Specifications and Methods of Test for Safety Glazing Materials Used in Buildings, ANSI Z97.1-

[40 FR 58752, Dec. 18, 1975. Redesignated at 44 FR 20679, Apr. 6, 1979, as amended at 52 FR 4581, Feb. 12, 1987. Redesignated at 58 FR 55004, Oct. 25, 1993]

Subpart C—Fire Safety

Source: 49 FR 32008, Aug. 9, 1984, unless otherwise noted.

§3280.201 Scope.

The purpose of this subpart is to set forth requirements that will assure reasonable fire safety to the occupants by reducing fire hazards and by providing measures for early detection.

§ 3280.202 Definitions.

The following definitions are applicable to subparts C, H, and I of the Standards:

Combustible material: Any material not meeting the definition of limited-combustible or non-combustible material.

Flame-spread rating: The measurement of the propagation of flame on the surface of materials or their assemblies as determined by recognized standard tests conducted as required by this subpart.

Interior finish: The surface material of walls, fixed or movable partitions, ceilings, columns, and other exposed interior surfaces affixed to the home's structure including any materials such as paint or wallpaper and the substrate to which they are applied. Interior finish does not include:

- (1) Trim and sealant 2 inches or less in width adjacent to the cooking range and in furnace and water heater spaces provided it is installed in accordance with the requirements of §3280.203(b)(3) or (4), and trim 6 inches or less in width in all other areas;
 - (2) Windows and frames:
- (3) Single doors and frames and a series of doors and frames not exceeding 5 feet in width:
 - (4) Skylights and frames;
- (5) Casings around doors, windows, and skylights not exceeding 4 inches in width;
- (6) Furnishings which are not permanently affixed to the home's structure;
- (7) Baseboards not exceeding 6 inches in height;
- (8) Light fixtures, cover plates of electrical receptacle outlets, switches, and other devices;
- (9) Decorative items attached to walls and partitions (i.e., pictures, decorative objects, etc.) constituting no more than 10% of the aggregate wall surface area in any room or space not more than 32 square feet in surface area, whichever is less:
- (10) Plastic light diffusers when suspended from a material which meets the interior finish provisions of §3280.203(b):
- (11) Coverings and surfaces of exposed wood beams; and
- (12) Decorative items including the following: